

From: "Bailey, Shawn" <SBailey@SempraGeneration.com>
To: <PletkaRJ@bv.com>, <MasonT@bv.com>,
<Claufenb@energy.state.ca.us>
CC: "Engelbrecht, William R." <WEngelbrecht@SempraGeneration.com>,
"Padilla,..."
Date: 4/4/2008 1:12 PM
Subject: Comments on RETI Phase 1A Report

Sempra Generation has two comments on the Phase 1A report related to wind and solar resources that should be considered in establishing the project work scope.

First, the report proposes to neglect consideration of solar photovoltaic resources outside of California. While the magnitude of potential regional solar PV resource is large, the study should at a minimum, consider those out-of-state renewable resources that have submitted interconnection applications to control areas contiguous to the CAISO (i.e. in Arizona and Nevada). This change will provide more consistent treatment of out-of-state solar PV and solar thermal resources.

Second, wind resources in Arizona should be included in the study scope. According to Table 1-2 of the report, Arizona accounts for over 2500MW of wind potential, which is significant and yet not unduly burdensome to the process.

Thanks for the opportunity to provide comments.

Shawn Bailey

Director - Planning & Analysis
Sempra Generation
101 Ash St., San Diego, CA 92101-3017
Office: 619 696-2962 Fax: 619-696-2119
Cell: 619 318-1458

sbailey@semprageneration.com <mailto:sbailey@semprageneration.com>

Sempra Generation is not the same company as the utility, SDG&E or SoCalGas, and the California Public Utilities Commission does not regulate the terms of Sempra Generation's products and services.